

# BLUFF VILLAS, HPR

## RECOMMENDED HVAC MAINTENANCE

---

In the interest of having a healthy HVAC System, it is recommended that you pour a mixture of **Clorox and water (4 ounces of Clorox mixed with 4 ounces of water)** into the inspection tube on your HVAC System.

**How often?**

**About every three months or four times a year.**

*Do this to greatly reduce the possibility of the HVAC System shutting down, caused by a blockage of algae growing in the HVAC drain system.*

*AND.... since our HVAC Systems share a common drain line, you not only help your system, you help your neighbors' systems as well.*

